

Emission Test Certificate

Monday, 23rd March 2015

Supplier: Carter Holt Harvey Pinepanels Pty Ltd (Jepsen Avenue, Tumut, NSW 2720)

Sample Description: STD MDF LPM

Date Tested: March 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Ecospecifier GreenTag	STD MDF LPM
Total Volatile Organic Compound Emission Rate limit <0.5mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.029 mg/m ² /hr
Formaldehyde Emission Rate limit <0.1mg/m ² /hr	Formaldehyde Emission Rate: 0.028 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV150302